



FORD METER BOX COMPANY MATERIALS LIST:

- 1) MONITOR COVER, Cat. No. MC-36-MB WITH LOCKING AND INNER LIDS.
- 2) POLYVINYL CHLORIDE (PVC) CYLINDER, 36" I.D. x 40" LENGTH WITH CUT-OUTS FOR SERVICE INLET AND OUTLET.
- 3) 70 SERIES COPPER SETTER WITH ANGLE BALL VALVE INLET AND ANGLE CHECK VALVE OUTLET, 27" HIGH WITH TWO (2) SUPPORT EYELETS, BYPASS BALL VALVE AND PACK-JOINT (CTS) INLET AND OUTLET CONNECTIONS.
Cat. No. VBH 76-27B-44-66 (1 1/2")
Cat. No. VBH 77-27B-44-77 (2")
- 4) BALL VALVE (1 1/2" OR 2" DIA.) WITH 9 1/2" STRAIGHT LEVER HANDLE.

NOTES:

- 1) MONITOR COVER IS NOT DESIGNED TO WITHSTAND TRAFFIC LOADS.
- 2) TO INSTALL 1 1/2" METER, USE TWO (2) 2" x 1 1/2" METER ADAPTERS.
- 3) BY-PASS VALVE MUST BE EXPOSED.

METER PIT ASSEMBLY FOR 1 1/2" AND 2" WATER METERS



CADD FILE: \\standard\details\water\mp002.dwg			
DATE: 3-28-2000	DRAWN BY: DTN	PAGE: 1 OF: 1	
REVISION:	DATE:	BY:	