



PLAN VIEW

NOTES:

1. THE MINIMUM DEPTH OF HYDRANT BURY SHALL BE 5 FEET, FROM FINISHED GRADE AT HYDRANT BARREL TO BOTTOM OF BASE.
2. GENERAL LOCATION OF THE HYDRANT ASSEMBLY IS AS SHOWN ON THE CONTRACT DRAWINGS. EXACT LOCATION OF HYDRANT ASSEMBLY SHALL BE DETERMINED BY THE ENGINEER AT THE TIME OF CONSTRUCTION. FOR BIDDING PURPOSES, MAXIMUM DISTANCE BETWEEN WATER MAIN AND FIRE HYDRANT IS TO BE 15 FEET.



CADD FILE: \standard\details\water\fh002.dwg		
DATE: 1-31-2000	DRAWN BY: DTN	PAGE: 1 OF: 1
REVISION:	DATE:	BY: