



**NOTES:**

- 1) MANHOLE DESIGN & CONSTRUCTION SHALL CONFORM TO ASTM C478, LATEST REVISION, FOR PRECAST REINFORCED CONCRETE MANHOLE SECTIONS.
- 2) CONCRETE COMPRESSIVE STRENGTH 4000 PSI MINIMUM.
- 3) PREFORMED AND FIELD FORMED CHANNELS SHALL BE NON-REINFORCED 4000 PSI CONCRETE.
- 4) WHERE MH. DEPTH FROM FINISHED GRADE TO INVERT IS LESS THAN 5 FT., A FLAT REINFORCED CONCRETE TOP WITH ECCENTRIC OPENING SHALL BE USED.
- 5) ALL MANHOLES SHALL BE INSTALLED WITH WRAPIDSEAL AS MANUFACTURED BY CANUSA PRIOR TO COMPLETION OF CONSTRUCTION - SEE SPECIFICATION FOR REQUIREMENTS.

**SANITARY SEWER AND SAMPLING MANHOLE**

N.T.S.



CADD FILE:		
Z: Autocad/Warminster Municipal Authority/Client Details/Details/Sewer/sm001		
DATE:	DRAWN BY:	PAGE: 1 OF: 1
6-21-2017	DTN	
REVISION:	DATE:	BY: